



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

Certificate of Analysis

Report To: Deep Bay Waterworks Dist.
Leslie
5031 Mountain View Road
Bowser, BC V0R 1G0

Lab Number: 87649
Date Reported: 25 May 11
Date Completed: 25 May 11
Date Received: 10 May 11 11:49

87649-01 Well #2

Sampled By: Ron
Sampling Date: 10 May 11 0:00

Test	Result	Units	Drinking Water Guideline
Alkalinity	17	mg/L (CaCO ₃)	
Total Ammonia (N)	<0.05	mg/L	
Chloride	2.2	mg/L	250 AO
Fluoride	<1.0	mg/L	1.5 MAC
Nitrate (N)	<0.1	mg/L	10 MAC
Nitrite (N)	<0.1	mg/L	1 MAC
Sulphate	<2.0	mg/L	500 AO
Colour - Apparent	<5	Colour units	
Conductivity	40.1	uS	
Iron Bacteria	None Detected	cfu/mL	
Sulphur Bacteria	None Detected	cfu/mL	
Corrosivity	-2.90		
T-Mercury	<0.00001	mg/L	0.001 MAC
pH	6.5	pH Units	6.5-8.5
Sulphide	<0.005	mg/L	0.05 AO
Total Coliforms (MF)	<1	CFU/100mL	<1
E. coli	<1	CFU/100mL	<1
Non-Coliform Background	<1	CFU/100mL	
Total Dissolved Solids	40	mg/L	500 AO
Total Organic Carbon	14.6	mg/L	
Total Organic Nitrogen	<0.08	mg/L	
Total Plate Count	<3	CFU/ml	
T-Aluminium	<0.005	mg/L	0.1 Operational Std
T-Antimony	<0.0002	mg/L	0.006 MAC
T-Arsenic	<0.0002	mg/L	0.010 MAC
T-Barium	<0.001	mg/L	1.0 MAC
T-Beryllium	<0.00004	mg/L	

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

25/05/2011 11:19

Page 1 of 4



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

87649-01 Well #2

Sampled By: Ron

Sampling Date: 10 May 11 0:00

Test	Result	Units	Drinking Water Guideline
T-Boron	<0.005	mg/L	5 MAC
T-Bismuth	<0.001	mg/L	
T-Cadmium	<0.00001	mg/L	0.005 MAC
T-Calcium	3.8	mg/L	
T-Chromium	0.0004	mg/L	0.05 MAC
T-Cobalt	<0.00002	mg/L	
T-Copper	0.003	mg/L	1.0 AO
T-Iron	<0.01	mg/L	0.3 AO
T-Lead	0.0006	mg/L	0.010 MAC
T-Lithium	<0.001	mg/L	
T-Magnesium	0.74	mg/L	
T-Manganese	<0.005	mg/L	0.05 AO
T-Molybdenum	<0.0001	mg/L	
T-Nickel	<0.001	mg/L	
T-Phosphorus	<0.01	mg/L	
T-Potassium	<0.1	mg/L	
T-Selenium	<0.0006	mg/L	0.01 MAC
T-Silicon	5.53	mg/L	
T-Silver	<0.00001	mg/L	
T-Sodium	2.79	mg/L	200 AO
T-Strontium	0.024	mg/L	
T-Thallium	<0.00001	mg/L	
T-Tin	0.0001	mg/L	
T-Titanium	0.001	mg/L	
T-Uranium	<0.0004	mg/L	
T-Vanadium	0.0008	mg/L	
T-Zinc	0.002	mg/L	5.0 AO
Hardness (CaCO ₃)	13	mg/L	80-100
Turbidity	1.1	NTU's	5 AO

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

25/05/2011 11:19

Page 2 of 4



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

87649-01

Test	Method	Analyst	Date
Alkalinity	Titration to 4.5, APHA based method	NiSL	12/05/2011
Chloride	TM6.1 APHA based	NiSL	11/05/2011
Colour - Apparent	Exova Subcontract Exova Subcontract	EXL	13/05/2011
Conductivity	Conductance meter	NiSL	13/05/2011
Corrosivity	Langelier Saturation Index, www.awwa.org	HE	24/05/2011
E. coli	Membrane Filtration, APHA 9222	NiSL	10/05/2011
Fluoride	TM6.1 APHA based	NiSL	11/05/2011
Hardness (CaCO ₃)	Exova subcontract Exova Subcontract	EXL	11/05/2011
Iron Bacteria	Subcontracted Test	MBL	10/05/2011
Nitrate (N)	TM6.1 APHA based	NiSL	11/05/2011
Nitrite (N)	TM6.1 APHA based	NiSL	11/05/2011
Non-Coliform Background	Membrane Filtration, APHA 9222	NiSL	10/05/2011
pH	pH meter	NiSL	12/05/2011
Sulphate	TM6.1 APHA based	NiSL	11/05/2011
Sulphide	Gas Dialysis APHA 4500-S2-E-Exova Subcontract	EXL	16/05/2011
Sulphur Bacteria	Subcontracted Test	MBL	10/05/2011
T-Aluminium	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Antimony	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Arsenic	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Barium	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Beryllium	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Bismuth	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Boron	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Cadmium	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Calcium	ICP, APHA 3120B Exova Subcontract	EXL	11/05/2011
T-Chromium	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Cobalt	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Copper	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Iron	ICP, APHA 3120B Exova Subcontract	EXL	11/05/2011
T-Lead	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Lithium	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Magnesium	ICP, APHA 3120B Exova Subcontract	EXL	11/05/2011
T-Manganese	ICP, APHA 3120B Exova Subcontract	EXL	11/05/2011
T-Mercury	Cold Vapor Atomic Absor, MDMES 245.1-Norwest Su	EXL	12/05/2011
T-Molybdenum	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

25/05/2011 11:19

Page 3 of 4



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

T-Nickel	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Phosphorus	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Potassium	ICP, APHA 3120B Exova Subcontract	EXL	11/05/2011
T-Selenium	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Silicon	ICP, APHA 3120B Exova Subcontract	EXL	11/05/2011
T-Silver	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Sodium	ICP, APHA 3120B Exova Subcontract	EXL	11/05/2011
T-Strontium	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Thallium	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Tin	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Titanium	ICP, APHA 3120B Exova Subcontract	EXL	11/05/2011
T-Uranium	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
T-Vanadium	ICP, APHA 3120B Exova Subcontract	EXL	11/05/2011
T-Zinc	ICP-MS, USEPA 200.8 Exova Subcontract	EXL	11/05/2011
Total Ammonia (N)	Exova Subcontract - APHA 4500-NH3 C based	EXL	16/05/2011
Total Coliforms (MF)	Membrane Filtration, APHA 9222	NIsL	10/05/2011
Total Dissolved Solids	gravimetric - Exova Subcontract	EXL	12/05/2011
Total Organic Carbon	Exova Subcontract Exova Subcontract	EXL	13/05/2011
Total Organic Nitrogen	Exova Subcontract Exova Subcontract	EXL	12/05/2011
Total Plate Count	MF-APHA 9215 D	NIsL	10/05/2011
Turbidity	Nephelometer	NIsL	10/05/2011

Approved By: 
Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC
> = Greater than; < = Less than
Results relate only to samples as submitted. This certificate must not be reproduced,
except in its entirety, without written consent from the laboratory.
Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

25/05/2011 11:19
Page 4 of 4