



Certificate of Analysis

Report To: Deep Bay Waterworks Dist.
Leslie
5031 Mountain View Road
Bowser, BC V0R 1G0

Lab Number: 98832
Date Reported: 1 Nov 12
Date Completed: 1 Nov 12
Date Received: 24 Oct 12 13:24

98832-01 Reservoir

Sampled By: Don Buchner
Sampling Date: 24 Oct 12 11:20

Test	Result	Units	Drinking Water Guideline
Total Ammonia (N)	<0.01	mg/L	
Total Coliforms (DES)	65.9	MPN/100mL	<1
E. coli (DES)	1.0	MPN/100mL	<1
Colour - Apparent	<1	Colour Units	15
pH	8.1	pH Units	6.5-8.5
Fluoride	<0.05	mg/L	1.5 MAC
Chloride	1.8	mg/L	250 AO
Nitrate (N)	0.12	mg/L	10 MAC
Nitrite (N)	<0.05	mg/L	1 MAC
Sulphate	0.8	mg/L	500 AO
T-Aluminium	0.011	mg/L	0.1 Operational Std.
T-Antimony	<0.0001	mg/L	0.006 MAC
T-Arsenic	0.00016	mg/L	0.010 MAC
T-Barium	0.00265	mg/L	1.0 MAC
T-Beryllium	<0.00005	mg/L	
T-Bismuth	0.0001	mg/L	
T-Boron	0.005	mg/L	5 IMAC
T-Cadmium	0.00001	mg/L	0.005 MAC
T-Calcium	18.3	mg/L	
T-Chromium	0.0008	mg/L	0.05 MAC
T-Cobalt	<0.0001	mg/L	
T-Copper	0.0017	mg/L	1.0 AO
T-Iron	0.01	mg/L	0.3 AO
T-Lead	0.0006	mg/L	0.010 MAC
T-Lithium	<0.0005	mg/L	
T-Magnesium	1.74	mg/L	
T-Manganese	0.0005	mg/L	0.05 AO

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 1 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

98832-01 Reservoir

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 11:20

Test	Result	Units	Drinking Water Guideline
T-Molybdenum	0.00009	mg/L	
T-Nickel	<0.0002	mg/L	
T-Potassium	0.5	mg/L	
T-Selenium	<0.0001	mg/L	0.01 MAC
T-Silicon	10.9	mg/L	
T-Silver	<0.00001	mg/L	
T-Sodium	4.1	mg/L	200 AO
T-Strontium	0.0478	mg/L	
T-Thallium	<0.00001	mg/L	
T-Tin	0.0002	mg/L	
T-Titanium	<0.0005	mg/L	
T-Uranium	0.00002	mg/L	0.02 MAC
T-Vanadium	0.0027	mg/L	
T-Zinc	0.0063	mg/L	5 AO
Hardness (CaCO ₃)	53	mg/L	
Tannins & Lignins	<0.1	mg/L	0.4 AO
UV Transmittance	100	%/cm	
Alkalinity	56	mg/L (CaCO ₃)	
Turbidity	<0.5	NTU's	5 AO
Total Dissolved Solids (conductivity ca	78	mg/L	500 AO

98832-02 Well # 1

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 9:00

Test	Result	Units	Drinking Water Guideline
Total Ammonia (N)	0.06	mg/L	
Total Coliforms (DES)	<1.0	MPN/100mL	<1
E. coli (DES)	<1.0	MPN/100mL	<1
Colour - Apparent	<1	Colour Units	15
pH	7.0	pH Units	6.5-8.5
Fluoride	<0.05	mg/L	1.5 MAC
Chloride	1.6	mg/L	250 AO
Nitrate (N)	<0.05	mg/L	10 MAC

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 2 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

98832-02 Well # 1

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 9:00

Test	Result	Units	Drinking Water Guideline
Nitrite (N)	<0.05	mg/L	1 MAC
Sulphate	0.6	mg/L	500 AO
T-Aluminium	0.006	mg/L	0.1 Operational Std.
T-Antimony	<0.0001	mg/L	0.006 MAC
T-Arsenic	<0.00005	mg/L	0.010 MAC
T-Barium	0.00081	mg/L	1.0 MAC
T-Beryllium	<0.00005	mg/L	
T-Bismuth	0.0001	mg/L	
T-Boron	0.003	mg/L	5 IMAC
T-Cadmium	0.00001	mg/L	0.005 MAC
T-Calcium	9.03	mg/L	
T-Chromium	0.0005	mg/L	0.05 MAC
T-Cobalt	<0.0001	mg/L	
T-Copper	0.0008	mg/L	1.0 AO
T-Iron	0.042	mg/L	0.3 AO
T-Lead	0.0003	mg/L	0.010 MAC
T-Lithium	<0.0005	mg/L	
T-Magnesium	2	mg/L	
T-Manganese	0.0009	mg/L	0.05 AO
T-Molybdenum	<0.00005	mg/L	
T-Nickel	<0.0002	mg/L	
T-Potassium	0.2	mg/L	
T-Selenium	<0.0001	mg/L	0.01 MAC
T-Silicon	9.99	mg/L	
T-Silver	<0.00001	mg/L	
T-Sodium	2.8	mg/L	200 AO
T-Strontium	0.0216	mg/L	
T-Thallium	<0.00001	mg/L	
T-Tin	0.0002	mg/L	
T-Titanium	<0.0005	mg/L	
T-Uranium	<0.00001	mg/L	0.02 MAC
T-Vanadium	0.0015	mg/L	
T-Zinc	0.043	mg/L	5 AO
Hardness (CaCO ₃)	31	mg/L	

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 3 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

98832-02 Well # 1

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 9:00

Test	Result	Units	Drinking Water Guideline
Tannins & Lignins	<0.1	mg/L	0.4 AO
UV Transmittance	100	%/cm	
Alkalinity	32	mg/L (CaCO ₃)	
Turbidity	0.7	NTU's	5 AO
Total Dissolved Solids (conductivity ca	49	mg/L	500 AO

98832-03 Well # 2

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 9:40

Test	Result	Units	Drinking Water Guideline
Total Ammonia (N)	<0.01	mg/L	
Total Coliforms (DES)	<1.0	MPN/100mL	<1
E. coli (DES)	<1.0	MPN/100mL	<1
Colour - Apparent	<1	Colour Units	15
pH	6.5	pH Units	6.5-8.5
Fluoride	<0.05	mg/L	1.5 MAC
Chloride	1.8	mg/L	250 AO
Nitrate (N)	<0.05	mg/L	10 MAC
Nitrite (N)	<0.05	mg/L	1 MAC
Sulphate	<0.5	mg/L	500 AO
T-Aluminium	0.003	mg/L	0.1 Operational Std.
T-Antimony	<0.0001	mg/L	0.006 MAC
T-Arsenic	<0.00005	mg/L	0.010 MAC
T-Barium	0.00024	mg/L	1.0 MAC
T-Beryllium	<0.00005	mg/L	
T-Bismuth	0.0001	mg/L	
T-Boron	0.002	mg/L	5 IMAC
T-Cadmium	0.00004	mg/L	0.005 MAC
T-Calcium	5.08	mg/L	
T-Chromium	0.0006	mg/L	0.05 MAC
T-Cobalt	<0.0001	mg/L	
T-Copper	0.002	mg/L	1.0 AO
T-Iron	0.07	mg/L	0.3 AO

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 4 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

98832-03 Well # 2

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 9:40

Test	Result	Units	Drinking Water Guideline
T-Lead	0.0009	mg/L	0.010 MAC
T-Lithium	<0.0005	mg/L	
T-Magnesium	0.94	mg/L	
T-Manganese	0.0016	mg/L	0.05 AO
T-Molybdenum	<0.00005	mg/L	
T-Nickel	<0.0002	mg/L	
T-Potassium	0.1	mg/L	
T-Selenium	<0.0001	mg/L	0.01 MAC
T-Silicon	7.18	mg/L	
T-Silver	<0.00001	mg/L	
T-Sodium	2.7	mg/L	200 AO
T-Strontium	0.0258	mg/L	
T-Thallium	<0.00001	mg/L	
T-Tin	0.0002	mg/L	
T-Titanium	<0.0005	mg/L	
T-Uranium	<0.00001	mg/L	0.02 MAC
T-Vanadium	0.0012	mg/L	
T-Zinc	0.0081	mg/L	5 AO
Hardness (CaCO ₃)	17	mg/L	
Tannins & Lignins	<0.1	mg/L	0.4 AO
UV Transmittance	100	%/cm	
Alkalinity	<20	mg/L (CaCO ₃)	
Turbidity	0.9	NTU's	5 AO
Total Dissolved Solids (conductivity ca	29	mg/L	500 AO

98832-04 Well # 3

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 9:20

Test	Result	Units	Drinking Water Guideline
Total Ammonia (N)	0.08	mg/L	
Total Coliforms (DES)	6.4	MPN/100mL	<1
E. coli (DES)	<1.0	MPN/100mL	<1
Colour - Apparent	4	Colour Units	15

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 5 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

98832-04 Well # 3

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 9:20

Test	Result	Units	Drinking Water Guideline
pH	6.9	pH Units	6.5-8.5
Fluoride	<0.05	mg/L	1.5 MAC
Chloride	0.8	mg/L	250 AO
Nitrate (N)	0.09	mg/L	10 MAC
Nitrite (N)	<0.05	mg/L	1 MAC
Sulphate	0.8	mg/L	500 AO
T-Aluminium	0.017	mg/L	0.1 Operational Std.
T-Antimony	<0.0001	mg/L	0.006 MAC
T-Arsenic	<0.00005	mg/L	0.010 MAC
T-Barium	0.00065	mg/L	1.0 MAC
T-Beryllium	<0.00005	mg/L	
T-Bismuth	0.0001	mg/L	
T-Boron	0.004	mg/L	5 IMAC
T-Cadmium	0.00002	mg/L	0.005 MAC
T-Calcium	9.71	mg/L	
T-Chromium	0.0006	mg/L	0.05 MAC
T-Cobalt	<0.0001	mg/L	
T-Copper	0.0012	mg/L	1.0 AO
T-Iron	0.071	mg/L	0.3 AO
T-Lead	0.0009	mg/L	0.010 MAC
T-Lithium	<0.0005	mg/L	
T-Magnesium	2.19	mg/L	
T-Manganese	0.002	mg/L	0.05 AO
T-Molybdenum	<0.00005	mg/L	
T-Nickel	0.0008	mg/L	
T-Potassium	0.2	mg/L	
T-Selenium	<0.0001	mg/L	0.01 MAC
T-Silicon	11.3	mg/L	
T-Silver	<0.00001	mg/L	
T-Sodium	3.2	mg/L	200 AO
T-Strontium	0.0259	mg/L	
T-Thallium	<0.00001	mg/L	
T-Tin	0.0002	mg/L	
T-Titanium	<0.0005	mg/L	

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 6 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

98832-04 Well # 3

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 9:20

Test	Result	Units	Drinking Water Guideline
T-Uranium	<0.00001	mg/L	0.02 MAC
T-Vanadium	0.0015	mg/L	
T-Zinc	0.0259	mg/L	5 AO
Hardness (CaCO ₃)	33	mg/L	
Tannins & Lignins	<0.1	mg/L	0.4 AO
UV Transmittance	99	%/cm	
Alkalinity	<20	mg/L (CaCO ₃)	
Turbidity	0.8	NTU's	5 AO
Total Dissolved Solids (conductivity ca	52	mg/L	500 AO

98832-05 Well # 4

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 10:00

Test	Result	Units	Drinking Water Guideline
Total Ammonia (N)	<0.01	mg/L	
Total Coliforms (DES)	2.0	MPN/100mL	<1
E. coli (DES)	<1.0	MPN/100mL	<1
Colour - Apparent	5	Colour Units	15
pH	6.7	pH Units	6.5-8.5
Fluoride	0.06	mg/L	1.5 MAC
Chloride	1.0	mg/L	250 AO
Nitrate (N)	0.09	mg/L	10 MAC
Nitrite (N)	<0.05	mg/L	1 MAC
Sulphate	1.0	mg/L	500 AO
T-Aluminium	0.003	mg/L	0.1 Operational Std.
T-Antimony	<0.0001	mg/L	0.006 MAC
T-Arsenic	<0.00005	mg/L	0.010 MAC
T-Barium	0.00067	mg/L	1.0 MAC
T-Beryllium	<0.00005	mg/L	
T-Bismuth	0.0001	mg/L	
T-Boron	0.003	mg/L	5 IMAC
T-Cadmium	0.00003	mg/L	0.005 MAC
T-Calcium	10	mg/L	

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 7 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

98832-05 Well # 4

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 10:00

Test	Result	Units	Drinking Water Guideline
T-Chromium	<0.0005	mg/L	0.05 MAC
T-Cobalt	<0.0001	mg/L	
T-Copper	0.0017	mg/L	1.0 AO
T-Iron	0.13	mg/L	0.3 AO
T-Lead	0.0007	mg/L	0.010 MAC
T-Lithium	<0.0005	mg/L	
T-Magnesium	2.26	mg/L	
T-Manganese	0.0033	mg/L	0.05 AO
T-Molybdenum	<0.00005	mg/L	
T-Nickel	<0.0002	mg/L	
T-Potassium	0.2	mg/L	
T-Selenium	<0.0001	mg/L	0.01 MAC
T-Silicon	11.9	mg/L	
T-Silver	<0.00001	mg/L	
T-Sodium	3.7	mg/L	200 AO
T-Strontium	0.029	mg/L	
T-Thallium	<0.00001	mg/L	
T-Tin	0.0002	mg/L	
T-Titanium	<0.0005	mg/L	
T-Uranium	<0.00001	mg/L	0.02 MAC
T-Vanadium	0.0012	mg/L	
T-Zinc	0.0082	mg/L	5 AO
Hardness (CaCO ₃)	34	mg/L	
Tannins & Lignins	<0.1	mg/L	0.4 AO
UV Transmittance	99	%/cm	
Alkalinity	40	mg/L (CaCO ₃)	
Turbidity	1.3	NTU's	5 AO
Total Dissolved Solids (conductivity ca	54	mg/L	500 AO

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 8 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

98832-06 Well # 5

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 10:40

Test	Result	Units	Drinking Water Guideline
Total Ammonia (N)	0.05	mg/L	
Total Coliforms (DES)	6.4	MPN/100mL	<1
E. coli (DES)	<1.0	MPN/100mL	<1
Colour - Apparent	<1	Colour Units	15
pH	7.2	pH Units	6.5-8.5
Fluoride	<0.05	mg/L	1.5 MAC
Chloride	2.0	mg/L	250 AO
Nitrate (N)	0.22	mg/L	10 MAC
Nitrite (N)	<0.05	mg/L	1 MAC
Sulphate	0.8	mg/L	500 AO
T-Aluminium	0.002	mg/L	0.1 Operational Std.
T-Antimony	<0.0001	mg/L	0.006 MAC
T-Arsenic	0.00012	mg/L	0.010 MAC
T-Barium	0.00162	mg/L	1.0 MAC
T-Beryllium	<0.00005	mg/L	
T-Bismuth	0.0001	mg/L	
T-Boron	0.004	mg/L	5 IMAC
T-Cadmium	0.00009	mg/L	0.005 MAC
T-Calcium	10.7	mg/L	
T-Chromium	0.0006	mg/L	0.05 MAC
T-Cobalt	<0.0001	mg/L	
T-Copper	0.0262	mg/L	1.0 AO
T-Iron	0.007	mg/L	0.3 AO
T-Lead	0.0022	mg/L	0.010 MAC
T-Lithium	<0.0005	mg/L	
T-Magnesium	3.23	mg/L	
T-Manganese	0.0005	mg/L	0.05 AO
T-Molybdenum	0.00008	mg/L	
T-Nickel	<0.0002	mg/L	
T-Potassium	0.4	mg/L	
T-Selenium	<0.0001	mg/L	0.01 MAC
T-Silicon	10.6	mg/L	
T-Silver	<0.00001	mg/L	
T-Sodium	3.3	mg/L	200 AO

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 9 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

98832-06 Well # 5

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 10:40

Test	Result	Units	Drinking Water Guideline
T-Strontium	0.0246	mg/L	
T-Thallium	<0.00001	mg/L	
T-Tin	0.0007	mg/L	
T-Titanium	<0.0005	mg/L	
T-Uranium	0.00001	mg/L	0.02 MAC
T-Vanadium	0.0025	mg/L	
T-Zinc	0.0192	mg/L	5 AO
Hardness (CaCO ₃)	40	mg/L	
Tannins & Lignins	<0.1	mg/L	0.4 AO
UV Transmittance	100	%/cm	
Alkalinity	42	mg/L (CaCO ₃)	
Turbidity	0.5	NTU's	5 AO
Total Dissolved Solids (conductivity ca	61	mg/L	500 AO

98832-07 Well # 6

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 10:20

Test	Result	Units	Drinking Water Guideline
Total Ammonia (N)	<0.01	mg/L	
Total Coliforms (DES)	<1.0	MPN/100mL	<1
E. coli (DES)	<1.0	MPN/100mL	<1
Colour - Apparent	5	Colour Units	15
pH	7.2	pH Units	6.5-8.5
Fluoride	<0.05	mg/L	1.5 MAC
Chloride	1.2	mg/L	250 AO
Nitrate (N)	<0.05	mg/L	10 MAC
Nitrite (N)	<0.05	mg/L	1 MAC
Sulphate	0.7	mg/L	500 AO
T-Aluminium	0.002	mg/L	0.1 Operational Std.
T-Antimony	<0.0001	mg/L	0.006 MAC
T-Arsenic	0.00016	mg/L	0.010 MAC
T-Barium	0.00147	mg/L	1.0 MAC
T-Beryllium	<0.00005	mg/L	

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 10 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

98832-07 Well # 6

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 10:20

Test	Result	Units	Drinking Water Guideline
T-Bismuth	0.0001	mg/L	
T-Boron	0.004	mg/L	5 IMAC
T-Cadmium	0.00001	mg/L	0.005 MAC
T-Calcium	11.7	mg/L	
T-Chromium	0.0006	mg/L	0.05 MAC
T-Cobalt	<0.0001	mg/L	
T-Copper	0.0007	mg/L	1.0 AO
T-Iron	0.051	mg/L	0.3 AO
T-Lead	0.0001	mg/L	0.010 MAC
T-Lithium	<0.0005	mg/L	
T-Magnesium	3.59	mg/L	
T-Manganese	0.0036	mg/L	0.05 AO
T-Molybdenum	0.0001	mg/L	
T-Nickel	<0.0002	mg/L	
T-Potassium	0.4	mg/L	
T-Selenium	<0.0001	mg/L	0.01 MAC
T-Silicon	11.3	mg/L	
T-Silver	<0.00001	mg/L	
T-Sodium	3.4	mg/L	200 AO
T-Strontium	0.0254	mg/L	
T-Thallium	<0.00001	mg/L	
T-Tin	0.0003	mg/L	
T-Titanium	<0.0005	mg/L	
T-Uranium	0.00001	mg/L	0.02 MAC
T-Vanadium	0.0025	mg/L	
T-Zinc	0.0039	mg/L	5 AO
Hardness (CaCO ₃)	44	mg/L	
Tannins & Lignins	<0.1	mg/L	0.4 AO
UV Transmittance	100	%/cm	
Alkalinity	46	mg/L (CaCO ₃)	
Turbidity	0.7	NTU's	5 AO
Total Dissolved Solids (conductivity ca	65	mg/L	500 AO

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 11 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

98832-08 Well # 8

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 11:00

Test	Result	Units	Drinking Water Guideline
Total Ammonia (N)	0.04	mg/L	
Total Coliforms (DES)	<1.0	MPN/100mL	<1
E. coli (DES)	<1.0	MPN/100mL	<1
Colour - Apparent	<1	Colour Units	15
pH	7.2	pH Units	6.5-8.5
Fluoride	0.06	mg/L	1.5 MAC
Chloride	1.9	mg/L	250 AO
Nitrate (N)	0.08	mg/L	10 MAC
Nitrite (N)	<0.05	mg/L	1 MAC
Sulphate	1.2	mg/L	500 AO
T-Aluminium	0.002	mg/L	0.1 Operational Std.
T-Antimony	<0.0001	mg/L	0.006 MAC
T-Arsenic	0.00012	mg/L	0.010 MAC
T-Barium	0.00134	mg/L	1.0 MAC
T-Beryllium	<0.00005	mg/L	
T-Bismuth	0.0001	mg/L	
T-Boron	0.003	mg/L	5 IMAC
T-Cadmium	0.00001	mg/L	0.005 MAC
T-Calcium	10.5	mg/L	
T-Chromium	0.0007	mg/L	0.05 MAC
T-Cobalt	<0.0001	mg/L	
T-Copper	0.0029	mg/L	1.0 AO
T-Iron	0.003	mg/L	0.3 AO
T-Lead	0.0001	mg/L	0.010 MAC
T-Lithium	<0.0005	mg/L	
T-Magnesium	3.1	mg/L	
T-Manganese	0.0004	mg/L	0.05 AO
T-Molybdenum	0.00005	mg/L	
T-Nickel	<0.0002	mg/L	
T-Potassium	0.4	mg/L	
T-Selenium	<0.0001	mg/L	0.01 MAC
T-Silicon	10.7	mg/L	
T-Silver	<0.00001	mg/L	
T-Sodium	3.2	mg/L	200 AO

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 12 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

98832-08 Well # 8

Sampled By: Don Buchner

Sampling Date: 24 Oct 12 11:00

Test	Result	Units	Drinking Water Guideline
T-Strontium	0.0246	mg/L	
T-Thallium	<0.00001	mg/L	
T-Tin	0.0002	mg/L	
T-Titanium	<0.0005	mg/L	
T-Uranium	0.00001	mg/L	0.02 MAC
T-Vanadium	0.0022	mg/L	
T-Zinc	0.0021	mg/L	5 AO
Hardness (CaCO ₃)	39	mg/L	
Tannins & Lignins	<0.1	mg/L	0.4 AO
UV Transmittance	100	%/cm	
Alkalinity	42	mg/L (CaCO ₃)	
Turbidity	<0.5	NTU's	5 AO
Total Dissolved Solids (conductivity ca	58	mg/L	500 AO

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 13 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

98832-01

Test	Method	Analyst	Date
Alkalinity	Titration to 4.5, APHA 2320 B -modified	NiSL	10/24/2012
Chloride	Ion Chromatography, EPA 300.1 -modified	NiSL	10/25/2012
Colour - Apparent	Spectrophotometer, APHA 2120 C -modified	NiSL	10/25/2012
E. coli (DES)	Enzyme Substrate, APHA 9223 B -modified	NiSL	10/24/2012
Fluoride	Ion Chromatography, EPA 300.1 -modified	NiSL	10/25/2012
Hardness (CaCO3)	Hardness by Calculation, APHA 2340 B -modified	NiSL	
Hardness (CaCO3)	Hardness by Calculation, APHA 2340 B -modified	NiSL	11/1/2012
Nitrate (N)	Ion Chromatography, EPA 300.1 -modified	NiSL	10/25/2012
Nitrite (N)	Ion Chromatography, EPA 300.1 -modified	NiSL	10/25/2012
pH	Electrometric, APHA 4500 B -modified	NiSL	10/24/2012
Sulphate	Ion Chromatography, EPA 300.1 -modified	NiSL	10/25/2012
T-Aluminium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Antimony	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Arsenic	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Barium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Beryllium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Bismuth	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Boron	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Cadmium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Calcium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Chromium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Cobalt	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Copper	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Iron	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Lead	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Lithium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Magnesium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Manganese	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Molybdenum	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Nickel	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Potassium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Selenium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Silicon	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Silver	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Sodium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 14 of 15



North Island Laboratories

• 2755 B Moray Avenue, Courtenay, B.C. V9N 8M9 Tel: (250) 338-7786 Fax: (250) 338-7553

T-Strontium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Thallium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Tin	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Titanium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Uranium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Vanadium	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
T-Zinc	Exova Subcontract, ICP-AES,EPA6010C,200.8-modified	EXL	10/29/2012
Tannins & Lignins	Exova Subcontract,Colorimetric,APHA 5550B-modified	EXL	10/29/2012
Total Ammonia (N)	Exova Subcontract, APHA 4500-NH3 C -modified	EXL	10/29/2012
Total Coliforms (DES)	Enzyme Substrate, APHA 9223 B -modified	NIsL	10/24/2012
Total Dissolved Solids (conducti	Conductivity @25C, APHA 2510 A -modified	NIsL	10/24/2012
Turbidity	Nephelometric, APHA 2130 B -modified	NIsL	10/25/2012
UV Transmittance	APHA 5910 C -modified	NIsL	10/25/2012

Approved By:

Catherine Black, Owner/Operator

AO = Aesthetic Objective; MAC = Max. Allowable Concentration; IMAC = Interim MAC

> = Greater than; < = Less than

Results relate only to samples as submitted. This certificate must not be reproduced, except in its entirety, without written consent from the laboratory.

Canadian Drinking Water Guidelines as listed on Dec. 5th, 2005 and are subject to

11/1/2012 15:07

Page 15 of 15