

TECHNICAL MEMO

To John Marsh, CPA, CMA – Administrator Deep Bay Improvement District	From Sean O'Connor, P.Eng. – Civil Division Manager
Re Deep Bay Improvement District Thompson Clarke West, Watermain Review	Date April 14, 2023


1. Introduction

McElhanney Ltd. (McElhanney) has been retained by the Deep Bay Improvement District (the District) to provide a watermain option review related to the trunk watermain located within a right-of-way on 4891 Thompson Clarke Drive West. This watermain replacement option review was triggered by the following:

- A portion of this watermain is located near the crest of an eroding embankment slope which was the subject of a slope stability assessment completed in November 2022. The watermain is at risk of damage / failure due to the eroding embankment slope and could also be at risk during potential slope stabilization repairs.
- This section of existing Asbestos Concrete (AC) watermain has been identified for replacement in the District's AC Watermain Replacement Program which was recently completed by McElhanney in April 2023.
- A portion of the existing watermain does not have legal tenure where it crosses 4891 Thompson Clarke Drive West to the south.

Refer to **Figure 1A** for details on the overall water service area and area serviced from the section of watermain in question. It should be noted that this section of 250mm diameter AC trunk watermain conveys water to the eastern end of the District.

DATE: 2023-03-24, 11:46 FILE: Z:\proj\active\27317-01 Deep Bay - Thompson Clark West Options Review\10.0 Drawings\10.3 Engineering\10.3.1 Sheets\27317-01-FIGURES.dwg McElhanney ANSID - 2015-04-01



NANAIMO REGIONAL DISTRICT BOUNDARY
COMOX-STRATHONA REGIONAL DISTRICT BOUNDARY

LEGEND

- WATER SERVICE AREA
- AREA OF INTEREST
- DISTRIBUTION MAIN
- TRUNK WATERMAIN
- RES STORAGE FACILITY

Rev	Date	Description	Drawn	Design	App'd
A	2023-03-24	ISSUED FOR MEMO		SO	

THIS DRAWING AND DESIGN IS THE PROPERTY OF McELHANNEY AND SHALL NOT BE USED, REUSED OR REPRODUCED WITHOUT THE CONSENT OF McELHANNEY. McELHANNEY WILL NOT BE HELD RESPONSIBLE FOR THE IMPROPER OR UNAUTHORIZED USE OF THIS DRAWING AND DESIGN.

THIS DRAWING AND DESIGN HAS BEEN PREPARED FOR THE CLIENT IDENTIFIED, TO MEET THE STANDARDS AND REQUIREMENTS OF THE APPLICABLE PUBLIC AGENCIES AT THE TIME OF PREPARATION. McELHANNEY, ITS EMPLOYEES, SUBCONSULTANTS AND AGENTS WILL NOT BE LIABLE FOR ANY LOSSES OR OTHER CONSEQUENCES RESULTING FROM THE USE OR RELIANCE UPON, OR ANY CHANGES MADE TO, THIS DRAWING, BY ANY THIRD PARTY, INCLUDING CONTRACTORS, SUPPLIERS, CONSULTANTS AND STAKEHOLDERS, OR THEIR EMPLOYEES OR AGENTS, WITHOUT McELHANNEY'S PRIOR WRITTEN CONSENT.

INFORMATION ON EXISTING UNDERGROUND FACILITIES MAY NOT BE COMPLETE OR ACCURATE. McELHANNEY, ITS EMPLOYEES AND DIRECTORS ARE NOT RESPONSIBLE NOR LIABLE FOR THE LOCATION OF ANY UNDERGROUND CONDUITS, PIPES, CABLES OR OTHER FACILITIES WHETHER SHOWN OR OMITTED FROM THIS PLAN. PRIOR TO CONSTRUCTION CONTRACTOR SHALL EXPOSE LOCATIONS OF ALL EXISTING FACILITIES BY HAND DIGGING OR HYDROVAC AND ADVISE THE ENGINEER OF POTENTIAL CONFLICTS.

0 1:7,500 400

ORIGINAL DWG SIZE: ANSID D (22" x 34")

McElhanney

Suite 1
1351 Estevan Road
Nanaimo BC
Canada V9S 3Y3
Tel 250 716 3336

**PRELIMINARY
NOT FOR
CONSTRUCTION**

THIS DRAWING HAS NOT BEEN APPROVED AND MAY CONTAIN ERRORS AND OMISSIONS

DEEP BAY IMPROVEMENT DISTRICT
5031 MOUNTAIN VIEW RD, BOWSER, BC V0R 1G0

**THOMPSON CLARK WEST
WATERMAIN OPTION WEST
WATER SERVICE AREA &
AREA OF INTEREST**

Drawing No. **FIGURE 1A**

Project Number 2231-27317-01-SK Rev. A

DESTROY ALL PRINTS BEARING PREVIOUS REVISION

2. Background

2.1. GENERAL

The Deep Bay Water System has been constructed in Phases over a period of approximately 5 decades, with most of the piping installed circa 1970's. Approximately 80% of the system was constructed using Asbestos Cement (AC) pipe and the remainder is Polyvinyl Chloride (PVC) pipe.

Most of the lines were constructed with 150 mm diameter pipe. Larger pipe was used along Gainsburg Road and Thompson Clarke Drive to provide a trunk main to feed water from the reservoir to the eastern end of the system.

The District has retained McElhanney to undertake a watermain review for the approximately 130m long section of 250mm diameter AC trunk watermain located within a right of way on 4891 Thompson Clarke Drive West. The intent of the review is to determine the following:

- Importance of the existing trunk watermain to the system's hydraulic capacity.
- Alternate replacement options to maintain the system's hydraulic capacity, and
- A preferred replacement option.

2.2. STUDY APPROACH / WORK PLAN

The work plan adopted for this study is as follows:

- Undertake a site visit to review the existing conditions and potential replacement routes / configurations.
- Undertake a system hydraulic model review to confirm if the trunk watermain is required and to confirm what adjacent upgrades are needed to maintain existing hydraulic capacity if this section is removed or abandoned.
- Undertake a replacement option review. This includes review / considerations on the following:
 - Horizontal and Vertical Alignment
 - Land Tenure Requirements
 - Environmental Impacts (high level)
 - Geotechnical Impacts (high level)
 - Permitting Requirements
 - Construction Cost Estimates

3. Analysis Criteria

In establishing the capacity of the distribution system, three levels of water demand are normally considered, in addition to fire flows. These are:

Average Day Demand (ADD) = $\frac{\text{Total annual consumption}}{365 \text{ days}}$

Maximum Day Demand (MDD) = Day with highest demand for the year

Peak Hour Demand (PHD) = Highest flow rate maintained for one hour
(generally occurring on maximum day of the year)

3.1. DISTRIBUTION SYSTEM

The water distribution system must be capable of delivering all demands as well as delivering fire flow demands during maximum day demands while operating within acceptable pressure ranges.

The criteria used for sizing the various water system components are provided in a number of the referenced standards and guideline documents. The 2008 Water System Evaluation report recommended the following design criteria for the Deep Bay Improvement District:

- Water distribution systems are sized to supply peak water consumption. The critical design criteria are typically based on either, Maximum Day Demand (MDD) plus Fire Flow or Peak Hour Demand (PHD).
- MDD plus Fire Flow is found to be the more stringent requirement for smaller water systems and has been used as the design case for this review.

3.1.1. Pressures & Velocities

The adequacy of the distribution system for various demand conditions is judged by the residual pressure available throughout the system and by the maximum velocity in the mains. The criteria applied to this study are listed in **Table 3-1** which are consistent with the MMCD standard requirements and previous District reporting.

Table 3-1: Pressure & Velocity Design Criteria

Parameter	Value	
Under Peak Hour Demand Conditions		
Minimum working pressure	275 kPa	(40 psi)
Maximum working pressure	700 kPa	(100 psi)
Maximum pipe velocity	2.0 m/s	(6.5 ft/s)
Under Fire Flow Demand Conditions (during Maximum Day Demands)		
Minimum residual pressure at hydrant	150 kPa	(22 psi)
Maximum pipe velocity	3.5 m/s	(11.5 ft/s)

3.1.2. Fire Flows

Fire flow requirements are presented for a typical single family residence using criteria outlined by Fire Underwriters Survey (FUS). The fire flow calculations to support this design fire flow are included in the 2008 Water System Evaluation Report (McElhanney). Calculation results for the Deep Bay Improvement District are presented in **Table 3-2**.

Table 3-2: Fire Flows based on Fire Underwriters Survey Guidelines

Location	Calculated Fire Flow
Single Family Residences	70 L/s (930 IGPM)

3.2. PROJECTED WATER DEMAND

Projected water demand for build-out of the un-developed land base was calculated in the 2008 Water System Evaluation Report (McElhanney) based on the current rates of consumption, projected growth, and peak factors. Future water demand is presented in **Table 3-3**.

Table 3-3: Projected Water Demand

Year	# of Services	Average Consumption	Average Day Demand (ADD)	Maximum Day Demand (MDD)	Peak Hour Demand (PHD)
2007	565	0.85 m ³ /service/ day	480 m ³ /day	1,440 m ³ /day	2,880 m ³ /day
		0.01 L/s/service	5.6 L/s	16.7 L/s	33.4 L/s
2030	1080	0.85 m ³ /service/ day	918 m ³ /day	2,754 m ³ /day	5,508 m ³ /day
		0.01 L/s/service	10.6 L/s	31.9 L/s	67.8 L/s



4. System Analysis

4.1. COMPUTER MODEL

A computer model that was previously developed for the Deep Bay Water System was transferred to a newer computer software program (WaterCAD) which was used to assess the capacity of a distribution system to meet delivery requirements.

WaterCAD is a powerful, user-friendly program created to analyse, design, and optimize water distribution systems. The program's many features include steady state and extended time modelling, multiple fire flow events modelling while evaluating flows and pressures across the entire system, and peak hour pressure analyses.

Model inputs define the physical characteristics of the system and the anticipated flows. The distribution system is modeled as a network of pipes interconnected at nodes. Pipes in the model are assigned the physical characteristics of pipes in the field (length, diameter and roughness), the nodes define the points of connection between the lines and define the points of water demand in the system (both domestic and fire flows).


The WaterCAD water model layout was developed to reflect the existing distribution system including various pipe sizes and materials. The computer model was updated to reflect distribution system upgrades including:

- Project: 27304, Longview & Shoreline Drive Watermain Replacement
- Project: 27311, Seaview Drive & Longview Drive Watermain Replacement

The water system layout including existing pipe size and materials is shown in **Figure 1B & 1C**.

The model was then used to assess a number of scenarios to review the hydraulic importance of the existing trunk watermain and replacement options that will maintain the existing hydraulic capacity of the system.

DATE: 2023-03-24, 14:56 FILE: Z:\proj\active\27317-01 Deep Bay - Thompson Clark West Options Review\10.3 Drawings\10.3 Engineering\10.3.1 Sheets\27317-01-FIGURES.dwg



LEGEND

- WATER SERVICE AREA
- 121 PIPE ### / NODE ##
- DISTRIBUTION MAIN
- TRUNK WATERMAIN
- RES STORAGE FACILITY

Rev	Date	Description	Drawn	Design	App'd
A	2023-03-24	ISSUED FOR MEMO		SO	

THIS DRAWING AND DESIGN IS THE PROPERTY OF McELHANNEY AND SHALL NOT BE USED, REUSED OR REPRODUCED WITHOUT THE CONSENT OF McELHANNEY. McELHANNEY WILL NOT BE HELD RESPONSIBLE FOR THE IMPROPER OR UNAUTHORIZED USE OF THIS DRAWING AND DESIGN.

THIS DRAWING AND DESIGN HAS BEEN PREPARED FOR THE CLIENT IDENTIFIED, TO MEET THE STANDARDS AND REQUIREMENTS OF THE APPLICABLE PUBLIC AGENCIES AT THE TIME OF PREPARATION. McELHANNEY, ITS EMPLOYEES, SUBCONSULTANTS AND AGENTS WILL NOT BE LIABLE FOR ANY LOSSES OR OTHER CONSEQUENCES RESULTING FROM THE USE OR RELIANCE UPON, OR ANY CHANGES MADE TO, THIS DRAWING, BY ANY THIRD PARTY, INCLUDING CONTRACTORS, SUPPLIERS, CONSULTANTS AND STAKEHOLDERS, OR THEIR EMPLOYEES OR AGENTS, WITHOUT McELHANNEY'S PRIOR WRITTEN CONSENT.

INFORMATION ON EXISTING UNDERGROUND FACILITIES MAY NOT BE COMPLETE OR ACCURATE. McELHANNEY, ITS EMPLOYEES AND DIRECTORS ARE NOT RESPONSIBLE NOR LIABLE FOR THE LOCATION OF ANY UNDERGROUND CONDUITS, PIPES, CABLES OR OTHER FACILITIES WHETHER SHOWN OR OMITTED FROM THIS PLAN. PRIOR TO CONSTRUCTION CONTRACTOR SHALL EXPOSE LOCATIONS OF ALL EXISTING FACILITIES BY HAND DIGGING OR HYDROVAC AND ADVISE THE ENGINEER OF POTENTIAL CONFLICTS.



ORIGINAL DWG SIZE: ANSI D (22" x 34")

McElhanney

Suite 1
1351 Estevan Road
Nanaimo BC
Canada V9S 3Y3
Tel 250 716 3336

PRELIMINARY
NOT FOR
CONSTRUCTION

THIS DRAWING HAS NOT BEEN APPROVED AND MAY CONTAIN ERRORS AND OMISSIONS

DEEP BAY IMPROVEMENT DISTRICT
5031 MOUNTAIN VIEW RD, BOWSER, BC V0R 1G0


THOMPSON CLARK WEST
WATERMAIN OPTION REVIEW
EXISTING WATER SYSTEM LAYOUT
PIPE & NODE PLAN (OVERVIEW)

Drawing No. **FIGURE 1B**

Project Number 2231-27317-01-SK Rev. A

DESTROY ALL PRINTS BEARING PREVIOUS REVISION

DATE: 2023-03-24, 21:57 FILE: Z:\p\active\27317-01 Deep Bay - Thompson Clark West Options Review\10.3 Drawings\10.3 Figures\10.3.1 Sheet\27317-01-FIGURES.dwg




LEGEND

- WATER SERVICE AREA
- 121 21 PIPE ### / NODE ##
- DISTRIBUTION MAIN
- TRUNK WATERMAIN
- RES STORAGE FACILITY

THIS DRAWING AND DESIGN IS THE PROPERTY OF McElhanney AND SHALL NOT BE USED, REUSED OR REPRODUCED WITHOUT THE CONSENT OF McELHANNEY. McELHANNEY WILL NOT BE HELD RESPONSIBLE FOR THE IMPROPER OR UNAUTHORIZED USE OF THIS DRAWING AND DESIGN.

THIS DRAWING AND DESIGN HAS BEEN PREPARED FOR THE CLIENT IDENTIFIED, TO MEET THE STANDARDS AND REQUIREMENTS OF THE APPLICABLE PUBLIC AGENCIES AT THE TIME OF PREPARATION. McELHANNEY, ITS EMPLOYEES, SUBCONSULTANTS AND AGENTS WILL NOT BE LIABLE FOR ANY LOSSES OR OTHER CONSEQUENCES RESULTING FROM THE USE OR RELIANCE UPON, OR ANY CHANGES MADE TO, THIS DRAWING, BY ANY THIRD PARTY, INCLUDING CONTRACTORS, SUPPLIERS, CONSULTANTS AND STAKEHOLDERS, OR THEIR EMPLOYEES OR AGENTS, WITHOUT McELHANNEY'S PRIOR WRITTEN CONSENT.

INFORMATION ON EXISTING UNDERGROUND FACILITIES MAY NOT BE COMPLETE OR ACCURATE. McELHANNEY, ITS EMPLOYEES AND DIRECTORS ARE NOT RESPONSIBLE NOR LIABLE FOR THE LOCATION OF ANY UNDERGROUND CONDUITS, PIPES, CABLES OR OTHER FACILITIES WHETHER SHOWN OR OMITTED FROM THIS PLAN. PRIOR TO CONSTRUCTION CONTRACTOR SHALL EXPOSE LOCATIONS OF ALL EXISTING FACILITIES BY HAND DIGGING OR HYDROVAC AND ADVISE THE ENGINEER OF POTENTIAL CONFLICTS.



ORIGINAL DWG SIZE: ANSI D (22" x 34")

McElhanney

Suite 1
1351 Estevan Road
Nanaimo BC
Canada V9S 3Y3
Tel 250 716 3336

PERMIT TO PRACTICE
McElhanney Ltd.
PERMIT NUMBER: 1003299
Engineers and Geoscientists of BC

Approved Sealed

DEEP BAY IMPROVEMENT DISTRICT
5031 MOUNTAIN VIEW RD, BOWSER, BC V0R 1G0

**THOMPSON CLARK WEST
WATERMAIN OPTION REVIEW
EXISTING WATER SYSTEM LAYOUT
PIPE & NODE PLAN**

Drawing No. **FIGURE 1C**

Project Number 2231-27317-01-SK Rev. A

DESTROY ALL PRINTS BEARING PREVIOUS REVISION

4.2. MODEL SCENARIOS

Several scenarios were assessed as part of the existing system hydraulic capacity review. The modeled scenarios are presented in **Table 4-1**.

Table 4-1: Water Model Scenarios


SCENARIO	SYSTEM ADJUSTMENTS	OBSERVATIONS
Scenario 1: Existing System, 2030 MDD (31.9 L/s), Determine Available Fire Flow	- Current Water System (including capital works since last model update)	System can generally deliver a fire flow of >70 L/s with a residual pressure of 150 kPa (20 psi), with the exception of several dead-end sections in the area of interest *
Scenario 2: Remove TCDW Trunk Main, 2030 MDD (31.9 L/s), Determine Available Fire Flow Figure 2	- Remove trunk watermain that runs through 4891 TCDW (Pipe 151) - Pipe 147 (150mm Diameter by-pass) kept in service	System can generally deliver a fire flow of 47 L/s with a residual pressure of 150 kPa (20 psi), with the exception of several dead-end sections in the area of interest.
Scenario 3: Add DL28 Main, 2030 MDD (31.9 L/s), Determine Available Fire Flow Figure 3	- Scenario 2 System Revisions - Add DL28 Main (Pipe 201, Length = 450m), 200mm Dia Main between Island Highway and Faye Road (Node 30 to 45)	System can generally deliver a fire flow of 47 L/s with a residual pressure of 150 kPa (20 psi), with the exception of several dead-end sections in the area of interest.
Scenario 4: Upsize Faye Road Watermain, 2030 MDD (31.9 L/s), Determine Available Fire Flow Figure 4	- Scenario 3 System Revisions - Replace Faye Road Watermain (Pipe 148 & 149, Length = 1000m), existing 150 PVC with 200mm Dia Main	System can generally deliver a fire flow of >70 L/s with a residual pressure of 150 kPa (20 psi), with the exception of several dead-end sections in the area of interest *
Scenario 5: Upsize from Gainsburg Trunk to DL28 Main, 2030 MDD (31.9 L/s), Determine Available Fire Flow Figure 5	- Scenario 4 System Revisions - Remove Pipe 147 (150mm Diameter by-pass from TCDW Trunk Main) - Upsize from Gainsburg Trunk to DL28 Main (Pipe 125, 127, 128, Length = 465m), existing 150 PVC with 200mm Dia Main	System can generally deliver a fire flow of >70 L/s with a residual pressure of 150 kPa (20 psi), with the exception of several dead-end sections in the area of interest *
Scenario 6: Replace TCDW Trunk Main, 2030 MDD (31.9 L/s), Determine Available Fire Flow Figure 6	- Restore Existing Water System Configuration with 250mm Diameter PVC Watermain (Pipe 146, 151, Length = 180 – 220m) - Alternate alignment(s) to avoid eroding embankment. Slope to be reviewed.	System can generally deliver a fire flow of >70 L/s with a residual pressure of 150 kPa (20 psi), with the exception of several dead-end sections in the area of interest *

* Several dead-end sections in the area of interest cannot achieve design fire flow of 70 L/s due to the max velocity criteria (a 150mm Dia. watermain can only provide 61 L/s @ 3.5 m/s)

The model results (available fire flows) are summarized in **Table A-1** which is included in **Appendix A**.



DATE: 2023-03-24, 14:58 FILE: Z:\proj\active\27317-01 Deep Bay - Thompson Clark West Options Review\10.3 Drawings\10.3 Figures\10.3.1 Sheet\27317-01-FIGURES.dwg
 McElhanney ANS D - 2019-04-01



LEGEND	
	WATER SERVICE AREA
	PIPE ### NODE ##
	DISTRIBUTION MAIN
	PROPOSED WATERMAIN
	WATERMAIN REMOVAL

Rev	Date	Description	Drawn	Design	App'd
A	2023-03-24	ISSUED FOR MEMO		SO	

THIS DRAWING AND DESIGN IS THE PROPERTY OF McELHANNEY AND SHALL NOT BE USED, REUSED OR REPRODUCED WITHOUT THE CONSENT OF McELHANNEY. McELHANNEY WILL NOT BE HELD RESPONSIBLE FOR THE IMPROPER OR UNAUTHORIZED USE OF THIS DRAWING AND DESIGN.

THIS DRAWING AND DESIGN HAS BEEN PREPARED FOR THE CLIENT IDENTIFIED, TO MEET THE STANDARDS AND REQUIREMENTS OF THE APPLICABLE PUBLIC AGENCIES AT THE TIME OF PREPARATION. McELHANNEY, ITS EMPLOYEES, SUBCONSULTANTS AND AGENTS WILL NOT BE LIABLE FOR ANY LOSSES OR OTHER CONSEQUENCES RESULTING FROM THE USE OR RELIANCE UPON, OR ANY CHANGES MADE TO, THIS DRAWING, BY ANY THIRD PARTY, INCLUDING CONTRACTORS, SUPPLIERS, CONSULTANTS AND STAKEHOLDERS, OR THEIR EMPLOYEES OR AGENTS, WITHOUT McELHANNEY'S PRIOR WRITTEN CONSENT.

INFORMATION ON EXISTING UNDERGROUND FACILITIES MAY NOT BE COMPLETE OR ACCURATE. McELHANNEY, ITS EMPLOYEES AND DIRECTORS ARE NOT RESPONSIBLE NOR LIABLE FOR THE LOCATION OF ANY UNDERGROUND CONDUITS, PIPES, CABLES OR OTHER FACILITIES WHETHER SHOWN OR OMITTED FROM THIS PLAN. PRIOR TO CONSTRUCTION CONTRACTOR SHALL EXPOSE LOCATIONS OF ALL EXISTING FACILITIES BY HAND DIGGING OR HYDROVAC AND ADVISE THE ENGINEER OF POTENTIAL CONFLICTS.

0 1:2,500 100

ORIGINAL DWG SIZE: ANS I D (22" x 34")

McElhanney

Suite 1
1351 Estevan Road
Nanaimo BC
Canada V9S 3Y3
Tel 250 716 3336

PRELIMINARY
NOT FOR
CONSTRUCTION

THIS DRAWING HAS NOT BEEN APPROVED AND MAY CONTAIN ERRORS AND OMISSIONS

DEEP BAY IMPROVEMENT DISTRICT
5031 MOUNTAIN VIEW RD, BOWSER, BC V0R 1G0


**THOMPSON CLARK WEST
TRUNK MAIN OPTION SCENARIOS
WATER MODEL SCENARIOS
SCENARIO 2**

Drawing No. **FIGURE 2**

Project Number 2231-27317-01-SK Rev. A

DESTROY ALL PRINTS BEARING PREVIOUS REVISION

DATE: 2023-03-24, 14:58 FILE: Z:\proj\active\27317-01 Deep Bay - Thompson Clark West Options Review\10.3 Drawings\10.3 Figures\10.3.1 Sheet\27317-01-FIGURES.dwg



LEGEND	
	WATER SERVICE AREA
	PIPE ### NODE ##
	DISTRIBUTION MAIN
	PROPOSED WATERMAIN
	WATERMAIN REMOVAL

Rev	Date	Description	Drawn	Design	App'd
A	2023-03-24	ISSUED FOR MEMO		SO	

THIS DRAWING AND DESIGN IS THE PROPERTY OF McElhanney AND SHALL NOT BE USED, REUSED OR REPRODUCED WITHOUT THE CONSENT OF McElhanney. McElhanney WILL NOT BE HELD RESPONSIBLE FOR THE IMPROPER OR UNAUTHORIZED USE OF THIS DRAWING AND DESIGN.

THIS DRAWING AND DESIGN HAS BEEN PREPARED FOR THE CLIENT IDENTIFIED, TO MEET THE STANDARDS AND REQUIREMENTS OF THE APPLICABLE PUBLIC AGENCIES AT THE TIME OF PREPARATION. McElhanney, ITS EMPLOYEES, SUBCONSULTANTS AND AGENTS WILL NOT BE LIABLE FOR ANY LOSSES OR OTHER CONSEQUENCES RESULTING FROM THE USE OR RELIANCE UPON, OR ANY CHANGES MADE TO, THIS DRAWING, BY ANY THIRD PARTY, INCLUDING CONTRACTORS, SUPPLIERS, CONSULTANTS AND STAKEHOLDERS, OR THEIR EMPLOYEES OR AGENTS, WITHOUT McElhanney's PRIOR WRITTEN CONSENT.

INFORMATION ON EXISTING UNDERGROUND FACILITIES MAY NOT BE COMPLETE OR ACCURATE. McElhanney, ITS EMPLOYEES AND DIRECTORS ARE NOT RESPONSIBLE NOR LIABLE FOR THE LOCATION OF ANY UNDERGROUND CONDUITS, PIPES, CABLES OR OTHER FACILITIES WHETHER SHOWN OR OMITTED FROM THIS PLAN. PRIOR TO CONSTRUCTION CONTRACTOR SHALL EXPOSE LOCATIONS OF ALL EXISTING FACILITIES BY HAND DIGGING OR HYDROVAC AND ADVISE THE ENGINEER OF POTENTIAL CONFLICTS.

0 1:2,500 100

ORIGINAL DWG SIZE: ANSI D (22" x 34")

McElhanney

Suite 1
1351 Estevan Road
Nanaimo BC
Canada V9S 3Y3
Tel 250 716 3336

PRELIMINARY
NOT FOR
CONSTRUCTION

THIS DRAWING HAS NOT BEEN APPROVED AND MAY CONTAIN ERRORS AND OMISSIONS

DEEP BAY IMPROVEMENT DISTRICT
5031 MOUNTAIN VIEW RD, BOWSER, BC V0R 1G0


**THOMPSON CLARK WEST
TRUNK MAIN OPTION SCENARIOS
WATER MODEL SCENARIOS
SCENARIO 3**

Drawing No. **FIGURE 3**

Project Number 2231-27317-01-SK Rev. A

DESTROY ALL PRINTS BEARING PREVIOUS REVISION

DATE: 2023-03-24, 14:59 FILE: Z:\proj\active\27317-01 Deep Bay - Thompson Clark West Options Review\10.3.1 Sheets\27317-01-FIGURES.dwg




LEGEND

	WATER SERVICE AREA
	PIPE ### NODE ##
	DISTRIBUTION MAIN
	PROPOSED WATERMAIN
	WATERMAIN REMOVAL

THIS DRAWING AND DESIGN IS THE PROPERTY OF McElhanney AND SHALL NOT BE USED, REUSED OR REPRODUCED WITHOUT THE CONSENT OF McElhanney. McElhanney WILL NOT BE HELD RESPONSIBLE FOR THE IMPROPER OR UNAUTHORIZED USE OF THIS DRAWING AND DESIGN.

THIS DRAWING AND DESIGN HAS BEEN PREPARED FOR THE CLIENT IDENTIFIED, TO MEET THE STANDARDS AND REQUIREMENTS OF THE APPLICABLE PUBLIC AGENCIES AT THE TIME OF PREPARATION. McElhanney, ITS EMPLOYEES, SUBCONSULTANTS AND AGENTS WILL NOT BE LIABLE FOR ANY LOSSES OR OTHER CONSEQUENCES RESULTING FROM THE USE OR RELIANCE UPON, OR ANY CHANGES MADE TO, THIS DRAWING, BY ANY THIRD PARTY, INCLUDING CONTRACTORS, SUPPLIERS, CONSULTANTS AND STAKEHOLDERS, OR THEIR EMPLOYEES OR AGENTS, WITHOUT McElhanney's PRIOR WRITTEN CONSENT.

INFORMATION ON EXISTING UNDERGROUND FACILITIES MAY NOT BE COMPLETE OR ACCURATE. McElhanney, ITS EMPLOYEES AND DIRECTORS ARE NOT RESPONSIBLE NOR LIABLE FOR THE LOCATION OF ANY UNDERGROUND CONDUITS, PIPES, CABLES OR OTHER FACILITIES WHETHER SHOWN OR OMITTED FROM THIS PLAN. PRIOR TO CONSTRUCTION CONTRACTOR SHALL EXPOSE LOCATIONS OF ALL EXISTING FACILITIES BY HAND DIGGING OR HYDROVAC AND ADVISE THE ENGINEER OF POTENTIAL CONFLICTS.



ORIGINAL DWG SIZE: ANSI D (22" x 34")

McElhanney

Suite 1
1351 Estevan Road
Nanaimo BC
Canada V9S 3Y3
Tel 250 716 3336

**PRELIMINARY
NOT FOR
CONSTRUCTION**

THIS DRAWING HAS NOT BEEN APPROVED AND MAY CONTAIN ERRORS AND OMISSIONS

DEEP BAY IMPROVEMENT DISTRICT
5031 MOUNTAIN VIEW RD, BOWSER, BC V0R 1G0


**THOMPSON CLARK WEST
WATERMAIN OPTION SCENARIOS
SCENARIO 4**

Drawing No. **FIGURE 4**

Project Number 2231-27317-01-SK Rev. A

DESTROY ALL PRINTS BEARING PREVIOUS REVISION

DATE: 2023-03-24, 14:59 FILE: Z:\proj\active\27317-01 Deep Bay - Thompson Clark West Options Review\10.3.1 Sheets\27317-01-FIGURES.dwg




LEGEND

	WATER SERVICE AREA
	PIPE ### NODE ##
	DISTRIBUTION MAIN
	PROPOSED WATERMAIN
	WATERMAIN REMOVAL

THIS DRAWING AND DESIGN IS THE PROPERTY OF McElhanney AND SHALL NOT BE USED, REUSED OR REPRODUCED WITHOUT THE CONSENT OF McElhanney. McElhanney WILL NOT BE HELD RESPONSIBLE FOR THE IMPROPER OR UNAUTHORIZED USE OF THIS DRAWING AND DESIGN.

THIS DRAWING AND DESIGN HAS BEEN PREPARED FOR THE CLIENT IDENTIFIED, TO MEET THE STANDARDS AND REQUIREMENTS OF THE APPLICABLE PUBLIC AGENCIES AT THE TIME OF PREPARATION. McElhanney, ITS EMPLOYEES, SUBCONSULTANTS AND AGENTS WILL NOT BE LIABLE FOR ANY LOSSES OR OTHER CONSEQUENCES RESULTING FROM THE USE OR RELIANCE UPON, OR ANY CHANGES MADE TO, THIS DRAWING, BY ANY THIRD PARTY, INCLUDING CONTRACTORS, SUPPLIERS, CONSULTANTS AND STAKEHOLDERS, OR THEIR EMPLOYEES OR AGENTS, WITHOUT McElhanney's PRIOR WRITTEN CONSENT.

INFORMATION ON EXISTING UNDERGROUND FACILITIES MAY NOT BE COMPLETE OR ACCURATE. McElhanney, ITS EMPLOYEES AND DIRECTORS ARE NOT RESPONSIBLE NOR LIABLE FOR THE LOCATION OF ANY UNDERGROUND CONDUITS, PIPES, CABLES OR OTHER FACILITIES WHETHER SHOWN OR OMITTED FROM THIS PLAN. PRIOR TO CONSTRUCTION CONTRACTOR SHALL EXPOSE LOCATIONS OF ALL EXISTING FACILITIES BY HAND DIGGING OR HYDROVAC AND ADVISE THE ENGINEER OF POTENTIAL CONFLICTS.



ORIGINAL DWG SIZE: ANSI D (22" x 34")

McElhanney

Suite 1
1351 Estevan Road
Nanaimo BC
Canada V9S 3Y3
Tel 250 716 3336

PRELIMINARY
NOT FOR
CONSTRUCTION

THIS DRAWING HAS NOT BEEN APPROVED AND MAY CONTAIN ERRORS AND OMISSIONS


DEEP BAY IMPROVEMENT DISTRICT
5031 MOUNTAIN VIEW RD, BOWSER, BC V0R 1G0

**THOMPSON CLARK WEST
WATERMAIN OPTION SCENARIOS
SCENARIO 5**

Drawing No.	FIGURE 5	
Project Number	2231-27317-01-SK	Rev. A

DESTROY ALL PRINTS BEARING PREVIOUS REVISION

DATE: 2023-03-24 - 22:04 FILE: Z:\p\h\active\27317-01 Deep Bay - Thompson Clark West Options Review\10.3 Drawings\10.3 Sheets\27317-01-FIGURES.dwg



REPLACE 250Ø TRUNK WATERMAIN, PIPE (146) & PIPE (151)

ALTERNATE REPLACEMENT ALIGNMENTS TO BE REVIEWED

SRW REQUIRED FOR EXISTING BY-PASS FROM TRUNK WATERMAIN, PIPE (147)

LEGEND

	WATER SERVICE AREA
	PIPE ### NODE ##
	DISTRIBUTION MAIN
	PROPOSED WATERMAIN
	WATERMAIN REMOVAL

THIS DRAWING AND DESIGN IS THE PROPERTY OF McElhanney AND SHALL NOT BE USED, REUSED OR REPRODUCED WITHOUT THE CONSENT OF McElhanney. McElhanney WILL NOT BE HELD RESPONSIBLE FOR THE IMPROPER OR UNAUTHORIZED USE OF THIS DRAWING AND DESIGN.

THIS DRAWING AND DESIGN HAS BEEN PREPARED FOR THE CLIENT IDENTIFIED, TO MEET THE STANDARDS AND REQUIREMENTS OF THE APPLICABLE PUBLIC AGENCIES AT THE TIME OF PREPARATION. McElhanney, ITS EMPLOYEES, SUBCONSULTANTS AND AGENTS WILL NOT BE LIABLE FOR ANY LOSSES OR OTHER CONSEQUENCES RESULTING FROM THE USE OR RELIANCE UPON, OR ANY CHANGES MADE TO, THIS DRAWING, BY ANY THIRD PARTY, INCLUDING CONTRACTORS, SUPPLIERS, CONSULTANTS AND STAKEHOLDERS, OR THEIR EMPLOYEES OR AGENTS, WITHOUT McElhanney'S PRIOR WRITTEN CONSENT.

INFORMATION ON EXISTING UNDERGROUND FACILITIES MAY NOT BE COMPLETE OR ACCURATE. McElhanney, ITS EMPLOYEES AND DIRECTORS ARE NOT RESPONSIBLE NOR LIABLE FOR THE LOCATION OF ANY UNDERGROUND CONDUITS, PIPES, CABLES OR OTHER FACILITIES WHETHER SHOWN OR OMITTED FROM THIS PLAN. PRIOR TO CONSTRUCTION CONTRACTOR SHALL EXPOSE LOCATIONS OF ALL EXISTING FACILITIES BY HAND DIGGING OR HYDROVAC AND ADVISE THE ENGINEER OF POTENTIAL CONFLICTS.

0 1:2,500 100

ORIGINAL DWG SIZE: ANSI D (22" x 34")

McElhanney

Suite 1
1351 Estevan Road
Nanaimo BC
Canada V9S 3Y3
Tel 250 716 3336

PRELIMINARY
NOT FOR
CONSTRUCTION

THIS DRAWING HAS NOT BEEN APPROVED AND MAY CONTAIN ERRORS AND OMISSIONS

DEEP BAY IMPROVEMENT DISTRICT
5031 MOUNTAIN VIEW RD, BOWSER, BC V0R 1G0

**THOMPSON CLARK WEST
TRUNK MAIN OPTION REVIEW
WATER MODEL SCENARIOS
SCENARIO 6**

Drawing No.
FIGURE 6

Project Number
2231-27317-01-SK

Rev.
A

DESTROY ALL PRINTS BEARING PREVIOUS REVISION

4.3. MODEL SCENARIOS FINDINGS

The findings from the scenario review are presented in **Table 4-2**.

Table 4-2: Water Model Scenario Findings

SCENARIO	SYSTEM ADJUSTMENTS	FINDINGS	COST CONSIDERATIONS	* COST ESTIMATE – CLASS ‘D’
Scenario 1	<ul style="list-style-type: none"> Existing System 	<ul style="list-style-type: none"> Base scenario for hydraulic comparison 	<ul style="list-style-type: none"> Slope restoration required 	\$155,000
Scenario 2	<ul style="list-style-type: none"> Remove TCDW Trunk Main (~140m of 250mm Dia. AC) 	<ul style="list-style-type: none"> Hydraulic capacity reduced; fire flow is generally < 47L/s 	<ul style="list-style-type: none"> Least expensive option but does not maintain existing hydraulic capacity 	-
Scenario 3	<ul style="list-style-type: none"> Scenario 2 + Add DL28 Main Connection (~450m of 200mm Dia. PVC) 	<ul style="list-style-type: none"> Hydraulic capacity reduced; fire flow is generally < 47L/s 	<ul style="list-style-type: none"> More expensive than Scenario 2 and does not maintain hydraulic capacity 	\$392,000
Scenario 4	<ul style="list-style-type: none"> Scenario 3 + Upsize Faye Rd Watermain (~1,000m of 200mm Dia. PVC) 	<ul style="list-style-type: none"> Hydraulic capacity maintained; fire flow is generally > 70L/s 	<ul style="list-style-type: none"> More expensive than Scenario 6 but does maintain hydraulic capacity 	\$1,655,000
Scenario 5	<ul style="list-style-type: none"> Scenario 4 + Remove TCDW Trunk Main (~160m of 250mm Dia. AC) Remove bypass from TCDW (~230m of 150mm Dia. PVC) Upsize from Gainsburg to DL28 Main (~465m of 200mm Dia. PVC) 	<ul style="list-style-type: none"> Hydraulic capacity maintained; fire flow is generally > 70L/s 	<ul style="list-style-type: none"> Most expensive option while maintaining hydraulic capacity 	\$2,242,295
Scenario 6	<ul style="list-style-type: none"> Replace Section of TCDW Trunk Main (~150m of 250mm Dia. PVC) 	<ul style="list-style-type: none"> Hydraulic capacity maintained; fire flow is generally > 70L/s 	<ul style="list-style-type: none"> Least expensive option while maintaining hydraulic capacity 	\$587,000

* Note: cost estimates do not include allowance for removal / decommissioning of existing watermains



5. Option Review (4891 Thompson Clarke Drive West)

Based on our review of the various scenarios, we find that, Scenario 6, replacing the existing trunk watermain along a similar alignment will be the most economical and practical replacement option that will maintain the existing hydraulic capacity in the water system. As such, we have reviewed potential replacement options.

5.1. OPTION 1

A conceptual design drawing (**Figure 7**) has been prepared to show scope of work related to Option 1. The option review considerations have been summarized below:

- Horizontal and Vertical Alignment
 - Follows similar alignment to existing trunk watermain but would be located away from eroding slope. It is anticipated that the RDN trail would be restored on top of the new alignment.
- Land Tenure Requirements
 - New SRW through 4891 Thompson Clarke Drive West would be required.
- Environmental Impacts (high level)
 - Drainage course crossing(s) and potential culvert extension would be required. If preferred the existing culvert(s) could be replaced. A Section 11 change approval or notification would be required depending on the scope of replacement.
 - Mature tree & vegetation removal would be required.
- Geotechnical Impacts (high level)
 - Existing eroding slope would need to be stabilized as part of the work. This would likely be done once the existing AC watermain is replaced and new watermain is in service.
- Permitting Requirements
 - MOTI Construction Permit would be required for the work within the Ministry right-of-way (Thompson Clarke Drive West & Ocean Trail).
 - Island Health Construction Permit would be required for the watermain replacement.
 - A Section 11 change approval or notification would be required depending on the impact on the nearby stream(s).
- Construction Cost Estimate
 - Cost Estimate – Class ‘D’ = \$ 587,000 (including contingency, excluding GST)



5.2. OPTION 2

A conceptual design drawing (**Figure 8**) has been prepared to show scope of work related to Option 2. The option review considerations have been summarized below:

- Horizontal and Vertical Alignment
 - Follows railway alignment with bends at either end to allow for connection to existing alignment. It is anticipated that the offset from the railway tracks would be about 4-6m (5.5m shown), however this would need to be reviewed with the Island Corridor Foundation (ICF) and Southern Railway of Vancouver Island (SVI).
- Land Tenure Requirements
 - License of Occupation from ICF would be required. The ICF would charge an annual fee in perpetuity for the License.
- Environmental Impacts (high level)
 - Drainage course crossings (existing culverts) would be required. A Section 11 change notification would be anticipated.
 - Drainage course crossing (large ditch) would be required near east end. A Section 11 approval may be required.
 - Significant mature tree & vegetation removal would be required.
- Geotechnical Impacts (high level)
 - Proposed alignment would be along the top of existing slope which would likely be disturbed during construction and would require significant stabilization.
- Permitting Requirements
 - MOTI Construction Permit would be required for the work within the Ministry right-of-way (Thompson Clarke Drive West & Ocean Trail).
 - Island Health Construction Permit would be required for the watermain replacement.
 - A Section 11 change approval and/or notification would be required depending on the impact on the nearby stream(s).
 - ICF Permitting would be required for the work in the railway corridor.
- Construction Cost Estimate
 - Cost Estimate – Class ‘D’ = \$ 706,500 (including contingency, excluding GST)



5.3. OPTION 3



A conceptual design drawing (**Figure 9**) has been prepared to show scope of work related to Option 3. The option review considerations have been summarized below:

- Horizontal and Vertical Alignment
 - First Segment: Follows railway alignment with bends at west end to allow for connection to existing alignment. It is anticipated that the offset from the railway tracks would be about 4-6m (5.5m shown), however this would need to be reviewed with the Island Corridor Foundation (ICF) and Southern Railway of Vancouver Island (SVI).
 - Transition: Proposed alignment transitions from railway grade to the existing trunk watermain alignment / grade to avoid impact on steep slope adjacent to railway.
 - Second Segment: Follows similar alignment to existing trunk watermain. It is anticipated that the RDN trail would be restored on top of the new alignment.
- Land Tenure Requirements
 - New SRW through 4891 Thompson Clarke Drive West would be required (limited to 20m section at east end).
 - License of Occupation from ICF would be required. The ICF would charge an annual fee in perpetuity for the License.
- Environmental Impacts (high level)
 - Drainage course crossing (existing culvert) would be required. If preferred the existing culvert could be replaced. A Section 11 change approval or notification would be required depending on the scope of replacement.
 - Significant mature tree & vegetation removal would be required.
- Geotechnical Impacts (high level)
 - Transition section from railway grade to existing trunk watermain alignment / grade would impact existing slope and the slope would need to be stabilized as part of the work.
- Permitting Requirements
 - MOTI Construction Permit would be required for the work within the Ministry right-of-way (Thompson Clarke Drive West & Ocean Trail).
 - Island Health Construction Permit would be required for the watermain replacement.
 - A Section 11 change approval or notification would be required depending on the impact on the nearby stream(s).
 - ICF Permitting would be required for the work in the railway corridor.
- Construction Cost Estimate
 - Cost Estimate – Class 'D' = \$ 705,500 (including contingency, excluding GST)



McElhanney ANS D - 23103-04-01

DATE: 2023-03-29, 08:28 FILE: Z:\proj\active\2317-01 Deep Bay - Thompson Clark West Options Review\10.3.1 Sheets\2317-01-FIGURES - OPTIONS.dwg



Rev	Date	Description	Drawn	Design	App'd
A	2023-03-24	ISSUED FOR MEMO		SO	

THIS DRAWING AND DESIGN IS THE PROPERTY OF McELHANNEY AND SHALL NOT BE USED, REUSED OR REPRODUCED WITHOUT THE CONSENT OF McELHANNEY. McELHANNEY WILL NOT BE HELD RESPONSIBLE FOR THE IMPROPER OR UNAUTHORIZED USE OF THIS DRAWING AND DESIGN.

THIS DRAWING AND DESIGN HAS BEEN PREPARED FOR THE CLIENT IDENTIFIED, TO MEET THE STANDARDS AND REQUIREMENTS OF THE APPLICABLE PUBLIC AGENCIES AT THE TIME OF PREPARATION. McELHANNEY, ITS EMPLOYEES, SUBCONSULTANTS AND AGENTS WILL NOT BE LIABLE FOR ANY LOSSES OR OTHER CONSEQUENCES RESULTING FROM THE USE OR RELIANCE UPON, OR ANY CHANGES MADE TO, THIS DRAWING, BY ANY THIRD PARTY, INCLUDING CONTRACTORS, SUPPLIERS, CONSULTANTS AND STAKEHOLDERS, OR THEIR EMPLOYEES OR AGENTS, WITHOUT McELHANNEY'S PRIOR WRITTEN CONSENT.

INFORMATION ON EXISTING UNDERGROUND FACILITIES MAY NOT BE COMPLETE OR ACCURATE. McELHANNEY, ITS EMPLOYEES AND DIRECTORS ARE NOT RESPONSIBLE NOR LIABLE FOR THE LOCATION OF ANY UNDERGROUND CONDUITS, PIPES, CABLES OR OTHER FACILITIES WHETHER SHOWN OR OMITTED FROM THIS PLAN. PRIOR TO CONSTRUCTION CONTRACTOR SHALL EXPOSE LOCATIONS OF ALL EXISTING FACILITIES BY HAND DIGGING OR HYDROVAC AND ADVISE THE ENGINEER OF POTENTIAL CONFLICTS.

ORIGINAL DWG SIZE: ANS I D (22" x 34")

McElhanney

Suite 1
1351 Estevan Road
Nanaimo BC
Canada V9S 3Y3
Tel 250 716 3336

PRELIMINARY
NOT FOR
CONSTRUCTION

THIS DRAWING HAS NOT BEEN APPROVED AND MAY CONTAIN ERRORS AND OMISSIONS

DEEP BAY IMPROVEMENT DISTRICT
5031 MOUNTAIN VIEW RD, BOWSER, BC V0R 1G0

**THOMPSON CLARK WEST
WATERMAIN OPTION REVIEW
WATERMAIN REPLACEMENT
OPTION 1**

Drawing No.
FIGURE 7



Project Number
2231-27317-01-SK

Rev.
A

DESTROY ALL PRINTS BEARING PREVIOUS REVISION

McElhanney ANS/D - 2015-04-01

DATE: 2023-03-29 08:28 FILE: Z:\proj\active\27317-01 Deep Bay - Thompson Clark West Options Review\10.3 Drawings\10.3 Figures - Options.dwg SHEET: 27317-01-FIGURES - OPTIONS.dwg



Rev	Date	Description	Drawn	Design	App'd
A	2023-03-24	ISSUED FOR MEMO		SO	

THIS DRAWING AND DESIGN IS THE PROPERTY OF McELHANNEY AND SHALL NOT BE USED, REUSED OR REPRODUCED WITHOUT THE CONSENT OF McELHANNEY. McELHANNEY WILL NOT BE HELD RESPONSIBLE FOR THE IMPROPER OR UNAUTHORIZED USE OF THIS DRAWING AND DESIGN.

THIS DRAWING AND DESIGN HAS BEEN PREPARED FOR THE CLIENT IDENTIFIED, TO MEET THE STANDARDS AND REQUIREMENTS OF THE APPLICABLE PUBLIC AGENCIES AT THE TIME OF PREPARATION. McELHANNEY, ITS EMPLOYEES, SUBCONSULTANTS AND AGENTS WILL NOT BE LIABLE FOR ANY LOSSES OR OTHER CONSEQUENCES RESULTING FROM THE USE OR RELIANCE UPON, OR ANY CHANGES MADE TO, THIS DRAWING, BY ANY THIRD PARTY, INCLUDING CONTRACTORS, SUPPLIERS, CONSULTANTS AND STAKEHOLDERS, OR THEIR EMPLOYEES OR AGENTS, WITHOUT McELHANNEY'S PRIOR WRITTEN CONSENT.

INFORMATION ON EXISTING UNDERGROUND FACILITIES MAY NOT BE COMPLETE OR ACCURATE. McELHANNEY, ITS EMPLOYEES AND DIRECTORS ARE NOT RESPONSIBLE NOR LIABLE FOR THE LOCATION OF ANY UNDERGROUND CONDUITS, PIPES, CABLES OR OTHER FACILITIES WHETHER SHOWN OR OMITTED FROM THIS PLAN. PRIOR TO CONSTRUCTION CONTRACTOR SHALL EXPOSE LOCATIONS OF ALL EXISTING FACILITIES BY HAND DIGGING OR HYDROVAC AND ADVISE THE ENGINEER OF POTENTIAL CONFLICTS.

ORIGINAL DWG SIZE: ANS/D (22" x 34")

McElhanney

Suite 1
1351 Estevan Road
Nanaimo BC
Canada V9S 3Y3
Tel 250 716 3336

PRELIMINARY
NOT FOR
CONSTRUCTION

THIS DRAWING HAS NOT BEEN APPROVED AND MAY CONTAIN ERRORS AND OMISSIONS

DEEP BAY IMPROVEMENT DISTRICT
5031 MOUNTAIN VIEW RD, BOWSER, BC V0R 1G0

THOMPSON CLARK WEST
WATERMAIN OPTION REVIEW
WATERMAIN REPLACEMENT
OPTION 2

Drawing No.
FIGURE 8



Project Number
2231-27317-01-SK

Rev.
A

DESTROY ALL PRINTS BEARING PREVIOUS REVISION

McElhanney ANS/D - 2015-04-01

DATE: 2023-03-29, 08:28 FILE: Z:\proj\active\27317-01 Deep Bay - Thompson Clark West Options Review\10.0 Drawings\10.3 Sheets\27317-01-FIGURES - OPTIONS.dwg



Rev	Date	Description	Drawn	Design	App'd
A	2023-03-24	ISSUED FOR MEMO		SO	

THIS DRAWING AND DESIGN IS THE PROPERTY OF McELHANNEY AND SHALL NOT BE USED, REUSED OR REPRODUCED WITHOUT THE CONSENT OF McELHANNEY. McELHANNEY WILL NOT BE HELD RESPONSIBLE FOR THE IMPROPER OR UNAUTHORIZED USE OF THIS DRAWING AND DESIGN.

THIS DRAWING AND DESIGN HAS BEEN PREPARED FOR THE CLIENT IDENTIFIED, TO MEET THE STANDARDS AND REQUIREMENTS OF THE APPLICABLE PUBLIC AGENCIES AT THE TIME OF PREPARATION. McELHANNEY, ITS EMPLOYEES, SUBCONSULTANTS AND AGENTS WILL NOT BE LIABLE FOR ANY LOSSES OR OTHER CONSEQUENCES RESULTING FROM THE USE OR RELIANCE UPON, OR ANY CHANGES MADE TO, THIS DRAWING, BY ANY THIRD PARTY, INCLUDING CONTRACTORS, SUPPLIERS, CONSULTANTS AND STAKEHOLDERS, OR THEIR EMPLOYEES OR AGENTS, WITHOUT McELHANNEY'S PRIOR WRITTEN CONSENT.

INFORMATION ON EXISTING UNDERGROUND FACILITIES MAY NOT BE COMPLETE OR ACCURATE. McELHANNEY, ITS EMPLOYEES AND DIRECTORS ARE NOT RESPONSIBLE NOR LIABLE FOR THE LOCATION OF ANY UNDERGROUND CONDUITS, PIPES, CABLES OR OTHER FACILITIES WHETHER SHOWN OR OMITTED FROM THIS PLAN. PRIOR TO CONSTRUCTION CONTRACTOR SHALL EXPOSE LOCATIONS OF ALL EXISTING FACILITIES BY HAND DIGGING OR HYDROVAC AND ADVISE THE ENGINEER OF POTENTIAL CONFLICTS.

ORIGINAL DWG SIZE: ANSI D (22" x 34")

McElhanney

Suite 1
1351 Estevan Road
Nanaimo BC
Canada V9S 3Y3
Tel 250 716 3336

PRELIMINARY
NOT FOR
CONSTRUCTION

THIS DRAWING HAS NOT BEEN APPROVED AND MAY CONTAIN ERRORS AND OMISSIONS

DEEP BAY IMPROVEMENT DISTRICT
5031 MOUNTAIN VIEW RD, BOWSER, BC V0R 1G0

**THOMPSON CLARK WEST
WATERMAIN OPTION REVIEW
WATERMAIN REPLACEMENT
OPTION 3**

Drawing No.
FIGURE 9

Project Number
2231-27317-01-SK

Rev.
A

DESTROY ALL PRINTS BEARING PREVIOUS REVISION

6. Findings & Recommendations

The following findings are summarized from our option review:

- Based on our review of the various scenarios, we find that, Scenario 6, replacing the existing trunk watermain along a similar alignment on 4891 Thompson Clarke Drive West and/or the Railway Corridor will be the most economical replacement option that will maintain the existing hydraulic capacity in the system.
- Based on our review of the various replacement options, we find that, Option 1, replacing the existing trunk watermain along a similar alignment on 4891 Thompson Clarke Drive West will be the most economical replacement option. In addition, this option has the least technical challenges.

We have the following recommendations based on the findings in our option review:

- Due to the potential impact on schedule and costs, it is recommended that the District review the conceptual design and required land acquisition with the property owner prior to proceeding with detailed design stage.
- Develop detailed design for the preferred replacement option (Option 1). Detailed design would generally consist of:
 - Phase 1: Preliminary Design (50% Design)
 - Topographic Survey and Base Drawings
 - Geotechnical Investigation (drilling)
 - Environmental Screening Report
 - Preliminary Design Drawings (50% Design)
 - Class 'C' Cost Estimate
 - Phase 2: 95% Detailed Design
 - 95% Design Drawings
 - Class 'B' Cost Estimate
 - Permit Applications
 - Phase 3: 100% Final Design
 - 100% Design Drawings
 - Class 'A' Cost Estimate



7. Closing

We trust that the information provided in this document is sufficient for your requirements. Should you have any questions or concerns, please do not hesitate to contact the undersigned.

Sincerely,


McElhanney Ltd.

EGBC Permit No. 1003299

Prepared by:

Reviewed by:

Sean O'Connor, P.Eng.
Project Manager
soconnor@mcelhanney.com | 778-762-0663



Chris Pogson, P.Eng.
Review Principal
cpogson@mcelhanney.com | 778-762-0667

Date	Status	Revision	Author
April 5, 2023	Draft for Client Review	Revision 00	S. O'Connor
April 14, 2023	Issued for Client Use	Revision 01	S. O'Connor



APPENDIX A

Model Results Summary

SYSTEM ANALYSIS - SCENARIO REVIEW

Table A-2: Available Fire Flow (MDD + Fire Flow) Comparison								
SYSTEM INFORMATION			SCENARIO 1	SCENARIO 2	SCENARIO 3	SCENARIO 4	SCENARIO 5	SCENARIO 6
Zone	Node	Elevation (m)	Fire Flow (Available) (L/s)	Fire Flow (Available) (L/s)	Fire Flow (Available) (L/s)	Fire Flow (Available) (L/s)	Fire Flow (Available) (L/s)	Fire Flow (Available) (L/s)
East Zone (Area of Interest)	71	23.0	61.1	47.0	47.3	61.1	61.1	61.1
	70	22.5	61.1	47.0	47.3	61.1	61.1	61.1
	69	33.3	61.3	47.0	47.3	61.3	61.3	61.3
	68	36.6	109.1	47.0	47.3	91.9	95.1	109.1
	67	32.1	99.5	47.0	47.3	91.9	95.1	99.5
	66	26.7	94.4	47.0	47.3	91.9	94.8	94.4
	65	28.0	27.4	27.4	27.4	27.4	27.4	27.4
	64	25.2	91.6	47.0	47.3	91.9	92.1	91.6
	63	26.1	87.2	47.0	47.3	87.7	87.7	87.2
	62	27.9	122.4	47.0	47.3	91.9	95.1	122.4
	61	37.4	136.6	47.0	47.3	91.9	95.1	136.6
	60	40.6	136.9	47.0	47.3	91.9	95.1	136.9
	59	43.6	137.1	47.0	47.3	91.9	95.1	137.1
	58	30.6	136.4	47.0	47.3	91.9	95.1	136.4
	57	26.2	135.3	47.0	47.3	91.9	95.1	135.3
	56	26.5	83.3	47.0	47.3	85.1	85.1	83.3
	55	13.0	27.4	27.4	27.4	27.4	27.4	27.4
	54	40.5	132.9	47.0	47.3	91.9	95.1	132.9
	53	40.9	126.2	47.0	47.3	91.9	95.1	126.2
	52	26.4	27.3	27.3	27.3	27.3	27.3	27.3
51	32.0	119.7	47.0	47.3	91.9	95.1	119.7	
50	42.4	119.3	47.0	47.3	91.9	95.1	119.3	
49	48.0	139.9	47.0	47.3	91.9	91.9	139.9	
48	47.8	61.7	47.0	47.3	61.7	61.7	61.7	
47	45.9	139.9	47.0	47.3	91.9	95.1	139.9	
46	49.9	122.0	47.0	47.3	91.9	95.1	122.0	
45	59.1	85.6	47.0	47.0	91.9	91.9	85.6	
	44	49.1	139.9	139.9	193.2	193.2	154.7	139.9
	43	49.5	27.2	27.2	27.2	27.2	27.2	27.2
	42	50.1	139.9	139.9	189.5	189.4	154.7	139.9
	41	47.1	139.9	139.9	177.8	177.8	154.7	139.9
	40	45.2	98.5	98.5	107.2	107.2	104.1	98.5
	39	37.4	85.7	85.7	92.1	92.1	90.4	85.7
	38	3.8	27.0	27.0	27.0	27.0	27.0	27.0
	37	3.8	27.4	27.4	27.4	27.4	27.4	27.4
	36	5.0	82.1	82.1	88.6	88.6	86.9	82.1
	35	27.7	82.1	82.1	88.6	88.6	86.9	82.1
	J-100	51.7	80.9	80.9	87.8	87.8	86.1	80.9

SYSTEM ANALYSIS - SCENARIO REVIEW

Table A-2: Available Fire Flow (MDD + Fire Flow) Comparison								
SYSTEM INFORMATION			SCENARIO 1	SCENARIO 2	SCENARIO 3	SCENARIO 4	SCENARIO 5	SCENARIO 6
Zone	Node	Elevation (m)	Fire Flow (Available) (L/s)	Fire Flow (Available) (L/s)	Fire Flow (Available) (L/s)	Fire Flow (Available) (L/s)	Fire Flow (Available) (L/s)	Fire Flow (Available) (L/s)
West Zone	J-101	52.5	80.8	80.8	87.7	87.7	86.0	80.8
	34	63.2	77.9	77.9	83.6	83.6	82.4	77.9
	33	61.3	73.9	73.8	79.5	79.5	78.5	73.9
	32	60.8	139.9	139.9	172.9	172.9	154.7	139.9
	31	43.0	61.9	61.9	100.1	100.1	95.1	61.9
	30	43.1	61.9	61.9	100.1	100.1	95.1	61.9
	29	43.8	61.9	61.9	100.3	100.3	95.1	61.9
	28	41.9	61.9	61.9	99.9	99.9	95.1	61.9
	27	64.9	27.5	27.5	27.5	27.5	95.1	27.5
	26	41.4	61.9	61.9	82.4	82.4	95.1	61.9
	24	65.7	215.5	215.5	215.5	215.5	215.5	215.5
	23	63.7	61.9	61.9	61.9	61.9	61.9	61.9
	22	92.1	61.0	61.0	61.0	61.0	61.0	61.0
	21	64.6	61.0	61.0	61.0	61.0	61.0	61.0
	20	59.8	109.1	109.1	109.1	109.1	109.1	109.1
	19	52.1	139.9	139.9	157.4	157.4	154.7	139.9
	18	64.5	139.9	139.9	158.7	158.7	154.7	139.9
	17	44.5	139.9	139.9	172.3	172.3	154.7	139.9
	16	37.0	51.9	51.9	51.9	51.9	51.9	51.9
	15	38.9	51.9	51.9	51.9	51.9	51.9	51.9
	14	34.2	51.9	51.9	51.9	51.9	51.9	51.9
	13	34.0	51.9	51.9	51.9	51.9	51.9	51.9
	12	62.7	27.5	27.5	27.5	27.5	27.5	27.5
	11	61.7	48.7	48.7	49.0	49.0	49.0	48.7
	10	33.4	51.9	51.9	51.9	51.9	51.9	51.9
	9	28.4	51.9	51.9	51.9	51.9	51.9	51.9
8	20.0	51.9	51.9	51.9	51.9	51.9	51.9	
7	4.7	27.3	27.3	27.3	27.3	27.3	27.3	
6	16.1	27.0	27.0	27.0	27.0	27.0	27.0	
5	7.6	51.9	51.9	51.9	51.9	51.9	51.9	
4	5.7	51.9	51.9	51.9	51.9	51.9	51.9	
3	3.8	51.9	51.9	51.9	51.9	51.9	51.9	
2	3.7	51.9	51.9	51.9	51.9	51.9	51.9	
1	3.8	26.8	26.8	26.8	26.8	26.8	26.8	

Available fire flows, while maintaining minimum residual pressure in system of 150 kPa (22 psi), less than design fire flow of 70 L/s

APPENDIX B

Cost Estimate – Class ‘D’

WATERMAIN REPLACEMENT - OPTION REVIEW

General Note: Cost estimate reflects construction of each conceptual option based on McElhanney Ltd. Conceptual Design Drawings dated March 24, 2023.			Class 'D' Cost Estimate (2023 Dollars)								
ITEM NO.	DESCRIPTION	UNIT	QUANTITY	UNIT PRICE	AMOUNT	QUANTITY	UNIT PRICE	AMOUNT	QUANTITY	UNIT PRICE	AMOUNT
			OPTION 1			OPTION 2			OPTION 3		
1.1	Mobilization and Demobilization	Lump Sum	1.0	\$50,000.00	\$50,000.00	1.0	\$50,000.00	\$50,000.00	1.0	\$50,000.00	\$50,000.00
1.2	Site Clearing	Lump Sum	1.0	\$30,000.00	\$30,000.00	1.0	\$35,000.00	\$35,000.00	1.0	\$50,000.00	\$50,000.00
1.3	Site Maintenance	Lump Sum	1.0	\$25,000.00	\$25,000.00	1.0	\$25,000.00	\$25,000.00	1.0	\$25,000.00	\$25,000.00
1.4	250mm Diameter Watermain (imported backfill, surface restoration)	Lineal Meter	200.0	\$600.00	\$120,000.00	235.0	\$600.00	\$141,000.00	225.0	\$600.00	\$135,000.00
1.5	Storm Drainage / Culvert Replacements (includes armouring)	Each	2.0	\$6,500.00	\$13,000.00	2.0	\$15,000.00	\$30,000.00	2.0	\$8,500.00	\$17,000.00
1.6	Associated Works (connections, appurtenances)	Lump Sum	1.0	\$40,000.00	\$40,000.00	1.0	\$50,000.00	\$50,000.00	1.0	\$50,000.00	\$50,000.00
1.7	Slope Stabilization Works	Allowance	1.0	\$50,000.00	\$50,000.00	1.0	\$100,000.00	\$100,000.00	1.0	\$80,000.00	\$80,000.00
1.8	Creek Crossing(s) / Environmental Mitigation	Allowance	1.0	\$40,000.00	\$40,000.00	1.0	\$40,000.00	\$40,000.00	1.0	\$40,000.00	\$40,000.00
1.9	Trail Reconstruction	Lineal Meter	180.0	\$500.00	\$90,000.00	0.0	\$0.00	\$0.00	180.0	\$500.00	\$90,000.00
TOTAL CONSTRUCTED WORKS					\$458,000.00			\$471,000.00			\$537,000.00
ENGINEERING & CONTINGENCY (50%)					\$229,000.00			\$235,500.00			\$268,500.00
RDN CONTRIBUTION (TRAIL RE-CONSTRUCTION)					(\$100,000.00)			\$0.00			(\$100,000.00)
TOTAL PROJECT (LESS GST)					\$587,000.00			\$706,500.00			\$705,500.00



Notes:

- 1) Estimated costs are derived from recent experience on Vancouver Island, but there is no warranty that actual cost will not vary. McElhanney accepts no liability for actual cost which may vary from the estimated construction costs provided herein.
- 2) No allowance has been made for land acquisition costs, property negotiations or easements.

APPENDIX C

Statement of Limitations

Statement of Limitations

Use of this Report. This report was prepared by McElhanney Ltd. ("McElhanney") for the particular site, design objective, development and purpose (the "Project") described in this report and for the exclusive use of the client identified in this report (the "Client"). The data, interpretations and recommendations pertain to the Project and are not applicable to any other project or site location and this report may not be reproduced, used or relied upon, in whole or in part, by a party other than the Client, without the prior written consent of McElhanney. The Client may provide copies of this report to its affiliates, contractors, subcontractors and regulatory authorities for use in relation to and in connection with the Project provided that any reliance, unauthorized use, and/or decisions made based on the information contained within this report are at the sole risk of such parties. McElhanney will not be responsible for the use of this report on projects other than the Project, where this report or the contents hereof have been modified without McElhanney's consent, to the extent that the content is in the nature of an opinion, and if the report is preliminary or draft. This is a technical report and is not a legal representation or interpretation of laws, rules, regulations, or policies of governmental agencies.

Standard of Care and Disclaimer of Warranties. This report was prepared with the degree of care, skill, and diligence as would reasonably be expected from a qualified member of the same profession, providing a similar report for similar projects, and under similar circumstances, and in accordance with generally accepted engineering and scientific judgments, principles and practices. McElhanney expressly disclaims any and all warranties in connection with this report.

Information from Client and Third Parties. McElhanney has relied in good faith on information provided by the Client and third parties noted in this report and has assumed such information to be accurate, complete, reliable, non-fringing, and fit for the intended purpose without independent verification. McElhanney accepts no responsibility for any deficiency, misstatements or inaccuracy contained in this report as a result of omissions or errors in information provided by third parties or for omissions, misstatements or fraudulent acts of persons interviewed.

Independent Judgments. McElhanney will not be responsible for the independent conclusions, interpretations, interpolations and/or decisions of the Client, or others, who may come into possession of this report, or any part thereof. This restriction of liability includes decisions made to purchase, finance or sell land or with respect to public offerings for the sale of securities.